



**STATE OF SOUTH CAROLINA
DEPARTMENT OF EDUCATION**

MOLLY M. SPEARMAN
STATE SUPERINTENDENT OF EDUCATION

The Annual Meeting

**SOUTH CAROLINA SCHOOL FACILITIES
PLANNING AND CONSTRUCTION GUIDE
FACILITIES COMMITTEE**

Wednesday, February 19, 2020, 2:00 pm
Conference Call: 1-800-753-1965
Access Code: 7346262

AGENDA

- **Opening – Welcome**
- **Declaration of Quorum**
- **Approval of the Agenda**
- **Voting of the Agenda Item(s)**

Approval of changes for the 2020 SC School Facilities Planning and Construction Guide:

1. **Delete the following to remove the requirement for fire alarm cable to be in metallic conduit:**
SECTION 804.1 - ~~Fire alarm cable must be installed in metallic conduit.~~ If existing fire alarm conduit is reused but is too small to carry both the signal and audio cable, then:
 1. All signal cable must be routed through conduit.
 2. The audio circuit cable may be attached to the outside of the existing conduit when the audio cable is routed along the same path.

3. If the audio cable will run to a location beyond the existing fire alarm conduit, the audio cable must run in metallic conduit from the existing conduit to the notification device.

- **Adjournment**