

Name of School or Building	Approximate square footage	Approximate age, years	Roof	Exterior Walls	Exterior Windows	Exterior Accessibility	Exterior Doors
Alma Elementary School	34,250	60	Fair	Poor	Poor	Poor	Poor
Alma Elementary School Art Portable Classroom	800	30	Poor	Poor	Poor	Poor	Poor
B.D. Lee	55,000	60	Poor	Poor	Poor	Poor	Poor
Blacksburg High School 9th Grade Academy	40,000	20	Fair	Good	Good	Good	Good
Blacksburg High School Fieldhouse	2,000	40	Fair	Poor	Poor	Fair	Poor
Blacksburg High School Gymnasium	20,000	40	Fair	Fair	Fair	Fair	Fair
Blacksburg High School Main Building	80,000	40	Poor	Fair	Poor	Fair	Poor
Blacksburg Middle School	78,000	60	Fair	Poor	Poor	Poor	Poor
Blacksburg Primary School	62,000	15	Fair	Good	Good	Good	Good

Blasksburg Elementary School	63,000	15	Fair	Fair	Fair	Fair	Poor
Cherokee Career and Technology Center	60,000	50	Poor	Poor	Poor	Poor	Poor
Cherokee Career and Technology Center	20,000	50	Very Good	Poor	Poor	Poor	Poor
Cherokee County District Office	20,500	17	Fair	Good	Poor	Good	Good
Cherokee Career and Technology Center Building B	40,000	50	Poor	Poor	Poor	Poor	Poor
Copeland Learning Center	38,000	9	Good	Good	Good	Fair	Good
Corinth Elementary School	48,000	60	Fair	Fair	Poor	Fair	Fair
Corinth Elementary School Portable 1	1,000	30	Poor	Poor	Poor	Poor	Poor
Corinth Elementary School Portable 2	1,000	30	Poor	Poor	Poor	Poor	Poor
Corinth Elementary School Portable 3	1,000	30	Poor	Poor	Poor	Poor	Poor

Draytonville Elementary School	44,000	59	Fair	Fair	Poor	Fair	Fair
Ewing Middle School	80,000	50	Poor	Poor	Poor	Poor	Poor
Gaffney High School Fieldhouse 1	20,000	18	Good	Fair	Fair	Fair	Fair
Gaffney High School Fieldhouse 2	10,000	18	Good	Fair	Fair	Fair	Fair
Gaffney High School Main Building	375,000	18	Good	Fair	Poor	Fair	Fair
Gaffney High School Ninth Grade Building	68,000	18	Fair	Fair	Fair	Fair	Fair
Gaffney Middle School Gymnasium	30,000	30	Fair	Fair	Fair	Fair	Fair
Gaffney Middle School Main	134,000	57	Good	Fair	Fair	Fair	Fair
Gaucher Elementary Portable 1	1,000	30	Poor	Poor	Poor	Poor	Poor
Goucher ElementarySchool	29,000	61	Fair	Poor	Poor	Poor	Poor

Granard Middle School	82,000	59	Poor	Poor	Poor	Poor	Poor
Grassy Pond Elementary School	56,000	19	Poor	Fair	Fair	Fair	Fair
Grassy Pond Portable 1	1,000	30	Fair	Fair	Fair	Fair	Fair
Limestone Central Elementary Portable 1	1,000	20	Fair	Fair	Fair	Fair	Fair
Limestone Central Elementary School	53,000	19	New/Less than Not Operational year	Fair	Fair	Fair	Fair
Luther Vaughan Elementary School	56,000	40	New/Less than Not Operational year	Fair	Poor	Fair	Fair
Luther Vaughan Elementary School Portable 1	1,000	30	Poor	Poor	Poor	Poor	Poor
Luther Vaughan Elementary School Portable 2	1,000	30	Poor	Poor	Poor	Poor	Poor
Mary Bramlett Elementary School	56,000	62	Fair	Poor	Poor	Poor	Poor
Northwest Elementary School	58,000	19	Poor	Fair	Fair	Fair	Fair

[illegible]

Blacksburg Elementary School	Fair	Fair	Fair	Fair	Fair	Fair	Fair
Cherokee Career and Technology Center	Poor	Poor	Poor	Poor	Poor	Poor	N/A
Cherokee Career and Technology Center	N/A	Poor	Poor	N/A	N/A	N/A	N/A
Cherokee County District Office	Good	Good	Good	Good	N/A	N/A	N/A
Cherokee Career and Technology Center Building B	Poor	Poor	Poor	Poor	Poor	Poor	N/A
Copeland Learning Center	N/A	Good	Good	Good	Good	Good	N/A
Corinth Elementary School	Fair	Fair	Fair	Fair	Fair	Good	Good
Corinth Elementary School Portable 1	Poor	Poor	Poor	N/A	N/A	Poor	N/A
Corinth Elementary School Portable 2	Poor	Poor	Poor	N/A	N/A	Poor	N/A
Corinth Elementary School Portable 3	Poor	Poor	Poor	N/A	N/A	Poor	N/A

Draytonville Elementary School	Fair	Fair	Fair	Fair	Fair	Fair	Fair
Ewing Middle School	Poor	Poor	Poor	Poor	Poor	Poor	Poor
Gaffney High School Fieldhouse 1	Fair	Fair	N/A	N/A	N/A	N/A	N/A
Gaffney High School Fieldhouse 2	Fair	Fair	N/A	N/A	N/A	N/A	N/A
Gaffney High School Main Building	Poor	Fair	Fair	Fair	Fair	Fair	Fair
Gaffney High School Ninth Grade Building	Fair	Fair	Fair	Fair	Fair	Fair	N/A
Gaffney Middle School Gymnasium	Fair	Fair	Fair	N/A	N/A	N/A	Fair
Gaffney Middle School Main	Fair	Poor	Fair	Poor	Fair	Fair	N/A
Gaucher Elementary Portable 1	Poor	Poor	Poor	N/A	N/A	Poor	N/A
Goucher ElementarySchool	Poor	Poor	Fair	Poor	Poor	Fair	Good

Name of School or Building	Auditorium/ Multipurpose Area Condition	Kitchen Condition	Toilet Room Condition	Administration HVAC	Classroom HVAC	Other HVAC	Main Electrical Entrance
Alma Elementary School	Poor	Poor	Poor	Poor	Poor	Poor	Poor
Alma Elementary School Art Portable Classroom	N/A	N/A	Poor	Poor	N/A	N/A	Poor
B.D. Lee	Poor	Poor	Poor	Poor	Poor	Poor	Poor
Blacksburg High School 9th Grade Academy	N/A	N/A	Good	Good	Good	Good	Good
Blacksburg High School Fieldhouse	N/A	N/A	Poor	N/A	N/A	Poor	Poor
Blacksburg High School Gymnasium	N/A	N/A	Fair	N/A	N/A	Fair	Poor
Blacksburg High School Main Building	Poor	Poor	Fair	Fair	Fair	Fair	Poor
Blacksburg Middle School	Poor	Poor	Poor	Poor	Poor	Poor	Poor
Blacksburg Primary School	Good	Good	Good	Fair	Fair	Fair	Fair

Blasksburg Elementary School	N/A	Fair	Fair	Poor	Poor	Poor	Poor
Cherokee Career and Technology Center	N/A	Poor	Poor	Poor	Poor	Poor	Poor
Cherokee Career and Technology Center	N/A	N/A	Poor	N/A	N/A	Poor	Poor
Cherokee County District Office	N/A	N/A	Good	Fair	N/A	Fair	Good
Cherokee Career and Technology Center Building B	N/A	N/A	Poor	Poor	Poor	Poor	Poor
Copeland Learning Center	N/A	N/A	Good	Fair	Fair	N/A	Good
Corinth Elementary School	Fair	Fair	Fair	Poor	Poor	Poor	Poor
Corinth Elementary School Portable 1	N/A	N/A	Poor	N/A	Poor	N/A	N/A
Corinth Elementary School Portable 2	N/A	N/A	Poor	N/A	Poor	N/A	N/A
Corinth Elementary School Portable 3	N/A	N/A	Poor	N/A	Poor	N/A	N/A

Draytonville Elementary School	Poor	Fair	Poor	Fair	Fair	Poor	Good
Ewing Middle School	N/A	Poor	Poor	Poor	Poor	Poor	Poor
Gaffney High School Fieldhouse 1	N/A	N/A	Fair	Not Operational	Not Operational	Fair	Fair
Gaffney High School Fieldhouse 2	N/A	N/A	Fair	N/A	N/A	Fair	Fair
Gaffney High School Main Building	Fair	Fair	Fair	Fair	Fair	Poor	Fair
Gaffney High School Ninth Grade Building	N/A	Fair	Fair	Fair	Fair	Fair	Fair
Gaffney Middle School Gymnasium	N/A	N/A	Fair	N/A	N/A	Fair	Fair
Gaffney Middle School Main	N/A	Fair	Poor	Poor	Poor	Poor	Poor
Gaucher Elementary Portable 1	N/A	N/A	Poor	N/A	Poor	N/A	N/A
Goucher ElementarySchool	N/A	Poor	Poor	Poor	Poor	Poor	Poor

Name of School or Building	Electrical Distribution	Lighting	Plumbing	Fire Alarm	Fire Sprinkler
Alma Elementary School	Poor	Poor	Poor	Poor	N/A
Alma Elementary School Art Portable Classroom	Poor	Poor	Poor	Poor	N/A
B.D. Lee	Poor	Poor	Poor	Poor	N/A
Blacksburg High School 9th Grade Academy	Good	Fair	Good	Good	Good
Blacksburg High School Fieldhouse	Poor	Poor	Poor	Poor	N/A
Blacksburg High School Gymnasium	Poor	Poor	Poor	Fair	N/A
Blacksburg High School Main Building	Poor	Poor	Poor	Poor	N/A
Blacksburg Middle School	Poor	Poor	Poor	Poor	N/A
Blacksburg Primary School	Fair	Fair	Good	Fair	Good

Blacksburg Elementary School	Poor	Poor	Poor	New/Less than Not Operational year	N/A
Cherokee Career and Technology Center	Poor	Poor	Poor	Poor	N/A
Cherokee Career and Technology Center	Poor	Poor	Poor	Poor	N/A
Cherokee County District Office	Good	Fair	Good	Fair	N/A
Cherokee Career and Technology Center Building B	Poor	Poor	Poor	Poor	N/A
Copeland Learning Center	Good	Good	Good	Good	Good
Corinth Elementary School	Poor	Poor	Fair	Fair	N/A
Corinth Elementary School Portable 1	Poor	Poor	Poor	Poor	N/A
Corinth Elementary School Portable 2	Poor	Poor	Poor	Poor	N/A
Corinth Elementary School Portable 3	Poor	Poor	Poor	Poor	N/A

Draytonville Elementary School	Poor	Fair	Fair	Fair	N/A
Ewing Middle School	Poor	Poor	Poor	Poor	N/A
Gaffney High School Fieldhouse 1	Fair	Fair	Fair	Fair	N/A
Gaffney High School Fieldhouse 2	Fair	Fair	Fair	Fair	N/A
Gaffney High School Main Building	Fair	Poor	Poor	Poor	N/A
Gaffney High School Ninth Grade Building	Fair	Poor	Fair	Fair	Fair
Gaffney Middle School Gymnasium	Fair	Fair	Fair	Fair	N/A
Gaffney Middle School Main	Poor	Poor	Poor	Poor	N/A
Gaucher Elementary Portable 1	Poor	Poor	Poor	Poor	N/A
Goucher ElementarySchool	Poor	Poor	Poor	Fair	N/A

Granard Middle School	Poor	Poor	Poor	Poor	N/A
Grassy Pond Elementary School	Fair	Poor	Fair	Fair	N/A
Grassy Pond Portable 1	Fair	Fair	Fair	Fair	N/A
Limestone Central Elementary Portable 1	Fair	Fair	Fair	Fair	N/A
Limestone Central Elementary School	Fair	Poor	Fair	Fair	N/A
Luther Vaughan Elementary School	Poor	Poor	Poor	Poor	N/A
Luther Vaughan Elementary School Portable 1	Poor	Poor	Poor	Poor	N/A
Luther Vaughan Elementary School Portable 2	Poor	Poor	Poor	Poor	N/A
Mary Bramlett Elementary School	Poor	Poor	Poor	Poor	N/A
Northwest Elementary School	Fair	Poor	Fair	Fair	N/A

Name of School or Building	Comments on building exterior
Alma Elementary School	Steel windows are corroded and are single pane
Alma Elementary School Art Portable Classroom	Portable classroom for Art class
B.D. Lee	This school is currently being replaced with the new facility under construction and designated to open next year
Blacksburg High School 9th Grade Academy	
Blacksburg High School Fieldhouse	
Blacksburg High School Gymnasium	
Blacksburg High School Main Building	Roof needs partial replacement.
Blacksburg Middle School	Building is old. Needs ADA update. Paving and drainage need update.Roof needs replacement. Windows need to be replaced
Blacksburg Primary School	

Blasksburg Elementary School	
Cherokee Career and Technology Center	Building is to be replaced in 2018. Design is now in progress
Cherokee Career and Technology Center	Building to be completely renovated in 2018. This is the district maintenance building
Cherokee County District Office	Windows need caulking and grouting. Paving needs to be reworked
Cherokee Career and Technology Center Building B	Building is to be replaced in 2018. Design is currently in progress
Copeland Learning Center	
Corinth Elementary School	Windows in bad condition
Corinth Elementary School Portable 1	
Corinth Elementary School Portable 2	
Corinth Elementary School Portable 3	

Draytonville Elementary School	Windows are in bad condition and are single pane.
Ewing Middle School	Roofing needs to be replaced. Windows need to be replaced. Paving and drainage need upgrading.
Gaffney High School Fieldhouse 1	
Gaffney High School Fieldhouse 2	
Gaffney High School Main Building	Windows are in poor condition. Roofing system has been recently replaced/repaired.Paving and drainage need to be repaired.
Gaffney High School Ninth Grade Building	
Gaffney Middle School Gymnasium	
Gaffney Middle School Main	Needs repair to drainage and pavement
Gaucher Elementary Portable 1	
Goucher ElementarySchool	Steel single pane window are in bad condition

Granard Middle School	Roof needs replacement. Paving and drainage need to be reworked.
Grassy Pond Elementary School	There are some paving and drainage problems. Roofing is poor and needs replacement
Grassy Pond Portable 1	
Limestone Central Elementary Portable 1	
Limestone Central Elementary School	New roof will be installed in summer. Present condition is very poor. A new Gym is presently under construction
Luther Vaughan Elementary School	Roof is new. Drop off canopy needed. Sidewalks and patio need to be implimented.
Luther Vaughan Elementary School Portable 1	
Luther Vaughan Elementary School Portable 2	
Mary Bramlett Elementary School	Very poor overall. Doors hardware does not meet ADA requirements.Needs improved grading for drainage.
Northwest Elementary School	Roof need replacement. A drop off canopy needs to be installed. Drainage is poor.

Name of School or Building	Comments on building accessibility
Alma Elementary School	Door hardware is old and doors are not keyed alike.
Alma Elementary School Art Portable Classroom	
B.D. Lee	
Blacksburg High School 9th Grade Academy	
Blacksburg High School Fieldhouse	
Blacksburg High School Gymnasium	
Blacksburg High School Main Building	
Blacksburg Middle School	Needs ADA update. Door hardware needs replacement. Needs a drop off canopy
Blacksburg Primary School	Needs entry and drop off canpoy

Blasksburg Elementary School	
Cherokee Career and Technology Center	
Cherokee Career and Technology Center	
Cherokee County District Office	
Cherokee Career and Technology Center Building B	
Copeland Learning Center	Needs a bus drop off canopy. Some paving needs repair
Corinth Elementary School	Parking is not adequate
Corinth Elementary School Portable 1	
Corinth Elementary School Portable 2	
Corinth Elementary School Portable 3	

Draytonville Elementary School	Door hardware need replacement
Ewing Middle School	Door hardware does not meet ADA requirements.
Gaffney High School Fieldhouse 1	
Gaffney High School Fieldhouse 2	
Gaffney High School Main Building	
Gaffney High School Ninth Grade Building	
Gaffney Middle School Gymnasium	
Gaffney Middle School Main	Door hardware does not meet ADA requirements
Gaucher Elementary Portable 1	
Goucher ElementarySchool	Need new canopy for loading and unloading students

Granard Middle School	No drop off canopy. Exterior doors are not ADA compliant.
Grassy Pond Elementary School	A drop off canopy in needed
Grassy Pond Portable 1	
Limestone Central Elementary Portable 1	
Limestone Central Elementary School	Drainage problem need to be addressed
Luther Vaughan Elementary School	Very poor Kindergarten assesibility
Luther Vaughan Elementary School Portable 1	
Luther Vaughan Elementary School Portable 2	
Mary Bramlett Elementary School	
Northwest Elementary School	Drop off canopy needs to be installed

Name of School or Building	Comments on building interior finishes
Alma Elementary School	Interior surfaces and finishes are poor.
Alma Elementary School Art Portable Classroom	
B.D. Lee	
Blacksburg High School 9th Grade Academy	
Blacksburg High School Fieldhouse	
Blacksburg High School Gymnasium	
Blacksburg High School Main Building	Entire building interior needs repainting. Carpet needs replacement in many areas. Science labs need update. Cafeteria need update of finishes. Leak in cafeteria needs to be repaired
Blacksburg Middle School	Needs complete interior upgrade.
Blacksburg Primary School	

Blasksburg Elementary School	
Cherokee Career and Technology Center	
Cherokee Career and Technology Center	
Cherokee County District Office	Some interior water damage needs to be repaired.
Cherokee Career and Technology Center Building B	
Copeland Learning Center	Some interior surfaces need to be refinished
Corinth Elementary School	Most interior finished are in bad condition
Corinth Elementary School Portable 1	
Corinth Elementary School Portable 2	
Corinth Elementary School Portable 3	

Draytonville Elementary School	Interior finished need work
Ewing Middle School	Interior finishes are poor and need to be reworked. Interior needs ADA upgrade.
Gaffney High School Fieldhouse 1	
Gaffney High School Fieldhouse 2	
Gaffney High School Main Building	Interior finished need update.
Gaffney High School Ninth Grade Building	
Gaffney Middle School Gymnasium	
Gaffney Middle School Main	Interior surfaces need to be updated
Gaucher Elementary Portable 1	
Goucher ElementarySchool	Interior finished need work

Granard Middle School	All interior surfaces need to be upgraded. Doors are not ADA compliant. Some auditorium seating is damaged and needs to be replaced
Grassy Pond Elementary School	Paining and finishes need to be repainted and reworked
Grassy Pond Portable 1	
Limestone Central Elementary Portable 1	
Limestone Central Elementary School	Interior finishes need to be adderessed
Luther Vaughan Elementary School	Interior finishes need improvement. Door hardware needs replacement.
Luther Vaughan Elementary School Portable 1	
Luther Vaughan Elementary School Portable 2	
Mary Bramlett Elementary School	All interior finished are in poor condition.Door hardware and plumbing fixtures do not meet ADA requirements. Most all casework needs replacement.
Northwest Elementary School	Interior surfaces need upgrade

Name of School or Building	Comments on MEP
Alma Elementary School	Mechanical and electrical equipment is past its useful age. Lighting is not efficient.
Alma Elementary School Art Portable Classroom	
B.D. Lee	
Blacksburg High School 9th Grade Academy	
Blacksburg High School Fieldhouse	
Blacksburg High School Gymnasium	
Blacksburg High School Main Building	HVAC needs replacement in some areas. Electrical and HVAC is dated and past useful life. Some kitchen equipment needs replacement.
Blacksburg Middle School	All MEP is very old and dated. It needs replacement. Kitchen equipment needs to be replaced.
Blacksburg Primary School	HVAC is reaching end of usefull life. Lighting is not efficient.

Blasksburg Elementary School	HVAC is nearing end of useful age. Lighting is not efficient
Cherokee Career and Technology Center	
Cherokee Career and Technology Center	
Cherokee County District Office	Lighting is not efficient.
Cherokee Career and Technology Center Building B	
Copeland Learning Center	
Corinth Elementary School	MEP systems are very old and need replacement
Corinth Elementary School Portable 1	
Corinth Elementary School Portable 2	
Corinth Elementary School Portable 3	

Draytonville Elementary School	HVAC equipment has exceeded it useful like. Lighting is inefficient. Electrical equipment need replacement.
Ewing Middle School	All MEP systems need replacement. Communication system needs to be replaced.
Gaffney High School Fieldhouse 1	
Gaffney High School Fieldhouse 2	
Gaffney High School Main Building	Lighting systems need replacement.They are not energy efficient. HVAC equipment is at the end of life and needs to be replaced.
Gaffney High School Ninth Grade Building	
Gaffney Middle School Gymnasium	
Gaffney Middle School Main	HVAC and Electrical equipment has exceeded normal life expectancy and needs to be replaced. Lighting is obsolete.
Gaucher Elementary Portable 1	
Goucher ElementarySchool	HVAC and electrical equipment is past its useful lifetime. Some kitchen equipment need replacement.Lighting needs replacement. Plumbing fixture need replacement.

Granard Middle School	All MEP equipment is past its normal life expectancy and should be replaced. Light fixtures are obsolete.
Grassy Pond Elementary School	Lighting is inefficient and needs replacement
Grassy Pond Portable 1	
Limestone Central Elementary Portable 1	
Limestone Central Elementary School	Lighting is inefficient and needs replacement. HVAC systems are nearing end of useful life.
Luther Vaughan Elementary School	MEP is reaching the end of useful life.Lighting is outdated and inefficient.
Luther Vaughan Elementary School Portable 1	
Luther Vaughan Elementary School Portable 2	
Mary Bramlett Elementary School	MEP is in poor condition. All systems need replacement.
Northwest Elementary School	Lighting is obsolete.

Name of School or Building	Comments on building life safety and security
Alma Elementary School	No fire sprinkler, old fire alarm system.
Alma Elementary School Art Portable Classroom	
B.D. Lee	No sprinkler system
Blacksburg High School 9th Grade Academy	Needs security update at vestibule and entry.
Blacksburg High School Fieldhouse	
Blacksburg High School Gymnasium	
Blacksburg High School Main Building	Security system needs update. No sprinkler system is installed
Blacksburg Middle School	No sprinkler system. Fire alarm is dated. Communication system needs to be replaced.
Blacksburg Primary School	

Blasksburg Elementary School	Not sprinklered and the fire alarm system is dated. Communication is poor and need replacement.
Cherokee Career and Technology Center	
Cherokee Career and Technology Center	
Cherokee County District Office	
Cherokee Career and Technology Center Building B	
Copeland Learning Center	
Corinth Elementary School	Fire alarm need replacement. No sprinkler system
Corinth Elementary School Portable 1	
Corinth Elementary School Portable 2	
Corinth Elementary School Portable 3	

Draytonville Elementary School	Building is not sprinklered.
Ewing Middle School	No sprinkler system is installed. Fire alarm is obsolete. Communication system needs replacement.
Gaffney High School Fieldhouse 1	
Gaffney High School Fieldhouse 2	
Gaffney High School Main Building	Only auditorium is sprinklered. Fire alarm needs replacement.Communication system need to be replaced.
Gaffney High School Ninth Grade Building	Building has Sprinkler system
Gaffney Middle School Gymnasium	
Gaffney Middle School Main	No sprinkler system is installed. Communication system needs to be replaced.
Gaucher Elementary Portable 1	
Goucher ElementarySchool	No sprinkler system. Communication system should be replaced

Granard Middle School	Administration area does not have a secure entry. No sprinkler system.
Grassy Pond Elementary School	No sprinkler system
Grassy Pond Portable 1	
Limestone Central Elementary Portable 1	
Limestone Central Elementary School	Building is not sprinklered
Luther Vaughan Elementary School	No sprinkler system. Communication system needs to be replaced. Fire alarm needs replacement.
Luther Vaughan Elementary School Portable 1	
Luther Vaughan Elementary School Portable 2	
Mary Bramlett Elementary School	Not sprinklered. Systems are in poor condition.
Northwest Elementary School	Building does not have a sprinkler system

Name of School or Building	
Alma Elementary School	
Alma Elementary School Art Portable Classroom	
B.D. Lee	
Blacksburg High School 9th Grade Academy	
Blacksburg High School Fieldhouse	
Blacksburg High School Gymnasium	
Blacksburg High School Main Building	
Blacksburg Middle School	
Blacksburg Primary School	

Blasksburg Elementary School	
Cherokee Career and Technology Center	
Cherokee Career and Technology Center	
Cherokee County District Office	
Cherokee Career and Technology Center Building B	
Copeland Learning Center	
Corinth Elementary School	
Corinth Elementary School Portable 1	
Corinth Elementary School Portable 2	
Corinth Elementary School Portable 3	

Draytonville Elementary School	
Ewing Middle School	
Gaffney High School Fieldhouse 1	
Gaffney High School Fieldhouse 2	
Gaffney High School Main Building	
Gaffney High School Ninth Grade Building	
Gaffney Middle School Gymnasium	
Gaffney Middle School Main	
Gaucher Elementary Portable 1	
Goucher ElementarySchool	

Granard Middle School	
Grassy Pond Elementary School	
Grassy Pond Portable 1	
Limestone Central Elementary Portable 1	
Limestone Central Elementary School	
Luther Vaughan Elementary School	
Luther Vaughan Elementary School Portable 1	
Luther Vaughan Elementary School Portable 2	
Mary Bramlett Elementary School	
Northwest Elementary School	