

The Twelfth Annual Meeting

**SOUTH CAROLINA PUBLIC SCHOOL
FACILITIES COMMITTEE**

**November 9, 2016, 10:00 A.M.
Rutledge Conference Center
Columbia, South Carolina**

AGENDA

Opening – Welcome

Declaration of Quorum

Reading and Approval of Minutes

Approval of the Agenda

Public Comment

Approval of changes for the 2017 SC School Facilities Planning and Construction Guide

Update edition and sections to align with the 2015 codes adopted by the General Assembly July 1, 2016

SECTION 108 BASIC CODES AND STANDARDS

Delete the following sections in their entirety:

Section 404.3.5 Toilet facilities must be located near the area served, but in no case more than a 200 foot travel distance.

Section 404.3.7.2 At least 50% of the required fixtures and all required accessible fixtures must be located within a 200 foot travel distance.

Section 404.3.7.3 The balance of the required fixtures must be located with no more than a 500 foot travel distance

Section 404.4.3 Bi-level water coolers must be counted as one fixture for fixture count purposes.

Section 603.1 All waste from kitchen areas except food grinder/garbage pulpers shall discharge through a grease trap.

Section 802.2.3 Lighting calculations must be based on a maximum total light loss maintenance factor (LLF) of 75%. Calculations must utilize reflectance values of the materials specified for the space.

Add the following new section:

Section 404.4.5 Security Door Hardware

Section 404.4.5.1 Security hardware for doors in addition to the lever entry sets used for door operation must be approved by the Office of School Facilities prior to installation.

Modify and add to the following section:

Section 804.1 Fire alarm cable must be installed in metallic conduit. If existing fire alarm conduit is reused but is too small to carry both the signal and audio cable, then:

1. All signal cable must be routed through conduit
2. The audio circuit cable may be attached to the outside of the existing conduit when the audio cable is routed along the same path.
3. If the audio cable must be run to a location beyond the existing fire alarm conduit, the audio cable must be run in metallic conduit from the existing conduit to the notification device.

Modify the FORM F3 to align with 2015 code

For Information – Toilet fixture counts for football venues

Mr. David Havird, Superintendent, Anderson School District One

Mr. Roger Lowe, Administrator, Building Codes Council

Adjournment